

Article

Multi-Objective Optimization Design of An Integrated Energy System with Ice Storage Based on Deep Reinforcement Learning

Xinyan Yang and Yu Li *

College of Environment Science and Engineering, Donghua University, Shanghai 201620, China;
2232481@mail.dhu.edu.cn (X.Y.)

* Corresponding author. E-mail: liyu@dhu.edu.cn (Y.L.)

Received: 22 May 2026; Revised: 9 June 2026; Accepted: 29 June 2026; Available online: 3 July 2026

ABSTRACT: This study proposes an integrated energy system that combines photovoltaic power, wind power, battery storage, and ice storage to meet the electricity and cooling demands of buildings. The model for the ice storage tank incorporates the nonlinear ice-melting characteristics. An improved Multi-Objective Proximal Policy Optimization algorithm is employed for multi-objective optimization. In a case study of an office building in Shanghai, the optimization results demonstrate that the proposed method reduces daily operating costs by 6.52% and improves the CO₂ emission reduction rate by 9.54%. The results demonstrate that the synergistic operation of electrical and ice storage effectively maintains supply-demand balance across different seasons. Sensitivity analysis further reveals that a 40% reduction in the unit cost of ice storage leads to a 5.7% decrease in battery capacity and a significant drop in grid dependency from 28.9% to 15.3%, highlighting the critical role of reducing ice storage costs in improving the system's economic viability and renewable energy integration capability.

Keywords: Integrated energy system; MOPPO; Ice storage; Multi-objective optimization

1. Introduction

Buildings account for over one-third of global energy consumption [1], significantly contributing to carbon emissions. To achieve carbon neutrality, transitioning building energy systems into distributed energy systems (DESSs) has become a critical pathway. By integrating renewable energy (RE) generation and energy storage systems (ESSs), DESSs can enhance energy efficiency and improve energy supply independence [2]. However, the intermittency of RE generation, dynamic load fluctuations [3], and thermoelectric coupling effects [4] pose substantial challenges in the optimal design of DESSs [5].

The power generation characteristics of RE sources such as photovoltaic (PV) and wind power are highly dependent on weather conditions [6], exhibiting inherent intermittency and volatility. PV output follows diurnal periodic patterns driven by solar irradiance but is subject to random variations caused by cloud cover. Wind power displays more pronounced stochastic variability due to spatiotemporal variations in wind speed. To predict the renewable energy generation, current research has primarily focused on two approaches: mathematical modeling and data-driven forecasting. Zhu et al. [7] applied a mathematical

model that linked PV output to solar irradiance and temperature, and correlated wind power with wind speed. By integrating equipment parameters and meteorological data, the model captures the dynamic behavior of RE generation. Hua et al. [8] employed stochastic modeling, characterizing wind speed variations using a Weibull distribution and solar irradiance fluctuations via a Beta distribution. Their probabilistic framework quantifies RE volatility through probability density functions (PDFs), assessing its impact on power system stability. With the widespread adoption of smart sensors, machine learning models have proven effective for PV generation forecasting [9] and short-term load profile prediction [10]. While early studies relied on conventional models such as autoregressive integrated moving average (ARIMA) and support vector machines (SVMs), recent advances in deep learning have demonstrated the superior temporal modeling capabilities of Long Short-Term Memory (LSTM) networks for RE prediction [11]. Wang et al. [12] developed an LSTM-based approach for PV forecasting that integrates ensemble empirical mode decomposition (EEMD) for data preprocessing and Bayesian optimization for hyperparameter tuning. Experimental results demonstrate the model's superior performance, achieving a root mean square error (RMSE) of 4.157 for 7-day-ahead forecasting, with a 15% improvement in accuracy over conventional methods. Chen et al. [13] developed an LSTM-based approach for wind power forecasting, which combines numerical weather prediction data with turbine monitoring measurements. The proposed LSTM model framework effectively captures temporal characteristics across multiple turbines, outperforming tradition prediction models in distributed wind farm applications.

The dynamic RE generation and fluctuating building loads often lead to supply-demand imbalance [14]. A notable example is the midday solar overgeneration contrasted with evening supply shortages, when PV output declines sharply, and wind generation may simultaneously drop to low levels [15]. To address the temporal mismatch between RE generation and energy demand, ESSs are essential for maintaining grid stability. Battery storage serves as the primary solution for storing surplus renewable electricity, which can then be discharged during periods of insufficient generation. For cooling-dominated buildings, ice thermal energy storage (ITES) systems offer distinct advantages by enabling the temporal shifting of cooling loads to periods of RE surplus, thereby enhancing renewable penetration [16]. This hybrid system, constructed on the principle of "renewable energy coupled with energy storage", not only achieves significant peak shaving and valley filling effects but also enhances the grid's absorption capacity for renewable energy through multi-energy complementarity [17]. Studies have revealed the significant benefits of such integrated systems. Saffari et al. [18] demonstrated that combining ITES with RE could result in a 30% annual cost savings. In a case study in Qatar [19,20], the combination of RE and ESS substantially reduced carbon emissions and gas dependency of the power system. Odufuwa et al. [21] developed a PV-integrated ice-thermal storage system. Its effectiveness was proved through optimization, resulting in approximately 33% annual energy cost savings. Christoph Luerssen et al. [22] assessed the net present value (NPV) of various PV-powered cooling system configurations. The results showed that the combination of RE with batteries and thermal storage significantly reduced fuel costs while achieving competitive economics. Similarly, Arévalo et al. [23] conducted a techno-economic evaluation of hybrid renewable systems combining photovoltaic, wind, hydrokinetic, and diesel sources, demonstrating that energy management strategies under site-specific conditions significantly affect system cost, emissions, and renewable penetration.

While hybrid energy systems integrate multiple devices to ensure energy supply, the design optimization of these systems is paramount for enhancing their efficiency, reliability, and economic viability. Conventional approaches typically determine equipment capacity based on peak load demands, resulting in system overcapacity and resource wastage [24]. To bridge the gap, advanced meta-heuristic algorithms have been widely adopted, including Particle Swarm Optimization (PSO) [25], Genetic Algorithms (GA) [26], Ant Colony Optimization (ACO) [27], and Evolutionary Mating Algorithm (EMA) [28]. Despite their effectiveness under specific conditions, metaheuristic algorithms exhibit notable limitations. One major drawback lies in their sensitivity to parameter settings. For instance, the performance

of PSO largely depends on the selection of inertia weights and learning factors, while the effectiveness of GA is strongly influenced by crossover and mutation rates. Improper parameter configurations can lead to slow convergence or even failure to converge, rendering these algorithms ineffective in handling dynamic models under complex environments [29].

Deep Reinforcement Learning (DRL) has emerged as a powerful approach for addressing the aforementioned challenges, as it is capable of executing autonomous decisions in complex environments [30]. DRL agents learn optimal control policies through continuous interaction with the environment [31]. This capability makes them particularly suitable for handling uncertainties in hybrid energy systems that integrate multiple sources for energy supply.

Among various DRL algorithms, Proximal Policy Optimization (PPO) has demonstrated superior stability and sample efficiency. It has been successfully tested in energy management [32]. In the context of low-carbon park energy dispatch, Ning et al. [33] developed a PPO-Mix Clip algorithm, with experimental results demonstrating a 3.52% reduction in daily operational costs. For the coordinated optimization of electric vehicles and smart homes, the HEN-PPO approach achieved energy savings ranging from 24% to 29% [34]. Le et al. [35] proposed the DAL-PPO method, which innovatively integrates energy efficiency optimization, indoor comfort maintenance, and system robustness enhancement into a unified reward function, with experimental findings indicating substantial performance improvements within the single-objective optimization framework.

Regarding multi-objective optimization, Ge et al. [36] proposed a multi-objective DRL (MODRL) method for scheduling of wind-solar-hydro-battery complementary system. Compared to NSGA-II, the solutions provided by the MODRL approach were closer to the true Pareto front (PF). However, significant research gaps persist in MODRL applications for building energy system design. Although conventional optimization methods can achieve multi-objective optimization in building energy systems, these approaches often rely on precise mathematical models and struggle to adapt to highly dynamic building energy environments. Deep reinforcement learning (DRL), with its capability to handle high-dimensional state spaces and learn complex nonlinear policies, is particularly suitable for addressing decision-making problems in multi-objective optimization of building energy systems. The development of building-oriented multi-objective DRL frameworks enables autonomous perception of environmental states and learning of optimal control strategies, effectively coordinating the trade-offs among economic viability, environmental sustainability, and energy efficiency. Such frameworks can effectively resolve inherent conflicting mechanisms among objectives and explore Pareto-optimal solution sets, thereby enabling holistic system-wide optimal design.

This study proposes an innovative design strategy for integrated energy systems with high renewable energy penetration by introducing an adaptive reward mechanism to dynamically balance multi-objective optimization. The main contributions are as follows: (1) A novel integrated energy system (IES) architecture is developed, incorporating PV and wind power generation units, a battery, and ITES devices with nonlinear ice-melting characteristics. A time series prediction model based on a LSTM neural network is established for renewable power generation forecasting. (2) The system incorporates an advanced ice thermal energy storage model that accounts for nonlinear ice-melting characteristics, accurately capturing the phase-change heat transfer process of ITES devices. (3) An improved Multi-Objective Proximal Policy Optimization (MOPPO) algorithm is proposed, employing life cycle cost (LCC), carbon dioxide emission reduction rate (CDERR), and renewable energy utilization (RU) as objective functions to optimize system capacity allocation. This algorithm searches for Pareto optimal solutions through policy gradient methods.

2. Methodology

This study proposes a hybrid methodology that integrates mathematical modeling and data-driven prediction to construct IES models, using an improved multi-objective reinforcement learning approach to

achieve multi-objective collaborative optimization. The research is structured around the following key areas: (1) Development of an IES: integrating LSTM neural network-based prediction models with physics-based mathematical models for system construction. (2) Optimal design of the IES: from a multi-objective perspective, prioritizing three primary objectives—economic efficiency, environmental impact, and energy sustainability, while accounting for the system’s operational constraints. (3) Solution methodology for the IES: The optimal design problem is formulated as a Markov Decision Process (MDP) through the definition of the state space, action space, and reward function, with optimal design solutions obtained through an improved reinforcement learning-based policy iteration optimization algorithm.

2.1. System Description

The overall system architecture and energy flow are illustrated in Figure 1. It presents an IES that incorporates PV, WT generation, ITES, battery storage, two types of dual-duty chillers with different rated cooling capacities, water pumps, and the power grid. The dual-duty chillers operate in a “daytime cooling and nighttime ice-making” mode, providing cooling services for buildings during the day and producing ice for thermal storage during periods of low nighttime electricity demand, thereby shifting energy consumption.




Figure 1. Energy flow in IES.

The operational logic is detailed in Figures 2 and 3. Solar energy and wind energy are converted into electricity by PV and wind turbines, which primarily supplies building electric loads. Excess electricity either charges the battery or powers the dual-duty chillers to generate cooling energy. When RE generation exceeds the total demand of electric loads and battery storage capacity, surplus electricity is fed back into the grid. If the RE output is insufficient, the battery is discharged first to compensate for the shortfall. In cases where battery storage capacity is inadequate, electricity is purchased from the grid.

During the cooling season (April to October), the ITES operates in ice charging mode at night when the electricity price is low. The dual-duty chillers convert electrical energy into stored cooling energy. During the daytime, when the electricity price is high, it switches to ice discharging mode, prioritizing the release of stored cooling energy to meet cooling loads. If the ice storage capacity is insufficient to cover cooling demand, the system automatically activates the chillers to provide supplementary cooling. Notably, when RE generation exceeds instantaneous electric load requirements, the system prioritizes utilizing

excess RE electricity to power the chillers for real-time cooling load. This mechanism reduces cooling costs during high-price periods while enhancing RE utilization efficiency.

Water pumps, as core components of the refrigerant circulation system, ensure efficient cooling energy transfer among chillers, ITES, and cooling loads. The power grid is a backup energy source, which ensures operational reliability in the system.




Figure 2. Operational logic diagram.




Figure 3. Cooling circuit operational logic diagram.

2.2. Modeling of IES Devices

This section aims to simulate energy flow dynamics within IES. The modeling comprises: output prediction modeling using LSTM for PV and wind turbines, and the establishment of physics-based mathematical models for equipment, such as chillers, ESSs, with particular attention to the modeling of ice storage devices incorporating nonlinear melting rate curves.

2.2.1. LSTM-Based Renewable Energy Prediction

As a specialized recurrent neural network architecture, the Long Short-Term Memory (LSTM) [37] network is employed in this study for RE generation forecasting due to its exceptional capability in modeling temporal dependencies and processing nonlinear sequential data. A simplified schematic diagram of the LSTM architecture is provided in Figure 4 to illustrate its operational principles. Compared to conventional Recurrent Neural Networks (RNNs), LSTM overcomes the vanishing gradient problem via its gating mechanisms [38], effectively capturing long-term dependencies in historical meteorological data and RE generation records. This advantage is particularly critical for RE forecasting tasks, as RE output exhibits pronounced diurnal and seasonal fluctuations influenced by meteorological factors such as solar irradiance, humidity, and wind speed [12].




Figure 4. The structure of LSTM cell.

The LSTM unit's core architecture consists of a cell state and three gating mechanisms (forget gate, input gate, output gate). Each unit processes three input parameters: the previous cell state C_{t-1} , current input x_t , and hidden state h_{t-1} .

The cell state serves as the primary information pathway, enabling direct temporal information propagation. The three gating mechanisms, implemented via sigmoid activation functions (yielding outputs between 0 and 1) and dot product operations, collectively regulate information flow by controlling the elimination of irrelevant information, the incorporation of relevant information, and the generation of the current output.

In this study, the LSTM model is designed to map historical time-series data to future power generation forecasts. Detailed descriptions of input data sources and prediction results are systematically addressed in the Case study section.

2.2.2. Cooling System Modelling

Chillers serve as the core refrigeration equipment in central cooling systems. Their energy consumption is strongly correlated with cooling capacity, operational efficiency, and part load ratio (PLR). The rated parameters of the dual-duty chiller model adopted in this study are listed in Table 1.

Table 1. Chiller rated parameters.

No.	Power (kW)	COP	Cooling Capacity (kW)
1	245	6.14	1502
2	664	5.82	3868
3	664	5.82	3868

The chiller model is developed using a multivariate gray-box modeling approach [33]. This model achieves high prediction accuracy for key operational parameters, including evaporating temperature, condensing temperature, and coefficient of performance (COP).

$$\text{COP} = \frac{r}{\left(\frac{t_c + 273.15}{t_e + 273.15} - 1\right)r + a_1 \frac{t_c + 273.15}{t_e + 273.15} - a_2} \quad (1)$$

$$r = \frac{Q_e}{Q} \quad (2)$$

$$t_e = t_{w,e,E} - \frac{Q_e}{F_e(G_{w,e})} \quad (3)$$

$$t_c = t_{w,c,E} + \frac{Q_c}{F_c(G_{w,c})} \quad (4)$$

$$P_{\text{chiller}} = \frac{Q_e}{\text{COP}} \quad (5)$$

$$F_c(G_{w,c}) = a_3 \cdot G_{w,c}^2 + a_4 \cdot G_{w,c} + a_5 \quad (6)$$

$$F_e(G_{w,e}) = a_6 \cdot G_{w,e}^2 + a_7 \cdot G_{w,e} + a_8 \quad (7)$$

where r is the real-time load ratio of the chiller. t_c and t_e represent the condensing temperature and evaporating temperature, respectively, °C. Q_c and Q_e are the real-time cooling capacity and real-time condensing heat output, respectively, kW. $t_{w,e,E}$ and $t_{w,c,E}$ indicate the chilled water inlet temperature and cooling water outlet temperature, respectively, °C. $G_{w,c}$ and $G_{w,e}$ correspond to the cooling water mass flow rate and chilled water mass flow rate, respectively, kg/s. $F(G_{w,c})$ and $F(G_{w,e})$ are empirical functions dependent on $G_{w,c}$ and $G_{w,e}$, respectively. Coefficients a_1 to a_8 are fitting parameters determined experimentally using measured data of evaporating temperature, condensing temperature, chilled and cooling water flow rates, and inlet and outlet water temperatures.

Water pumps in central cooling systems are primarily utilized to circulate cooling water or chilled water to critical components such as cooling towers and chillers, thereby maintaining the system's operational cycle. The rated parameters of the pumps in this system are summarized in Table 2.

Table 2. Pumps rated parameters.

Rated Parameters	Chilled Pump1	Chilled Pump2	Cooling Pump1	Cooling Pump2
Flow rate (m ³ /h)	730	280	865	350
Power (kW)	110	45	90	37
Pressure (m)	40	40	25	25
Frequency (Hz)	50	50	50	50

The energy consumption of chilled water pumps and cooling water pumps is predominantly governed by their flow rates, with the corresponding energy consumption models explicitly formulated in Equations (8) and (9).

$$P_c = b_1 \cdot G_{w,c}^2 + b_2 \cdot G_{w,c} + b_3 \quad (8)$$

$$P_e = b_4 \cdot G_{w,e}^2 + b_5 \cdot G_{w,e} + b_6 \quad (9)$$

where P_c and P_e are the power consumption of the cooling water pump and chilled water pump, respectively. $b_1 \sim b_6$ represent the fitting coefficients for the pump models.

Cooling towers serve as the critical component in the heat rejection process of central cooling systems. The rated parameters of the cooling towers in this system are summarized in Table 3.

Table 3. Cooling Tower rated parameters.

Rated Parameters	Value	Unit
Rated power	51	kW
Cooling capacity	2326	kW
Water flow rate	400	m ³ /h

The energy consumption model of cooling towers is similar to that of water pumps. It is developed based on their actual operating frequency, as suggested by existing literature. The corresponding energy consumption is expressed as shown in Equation (10).

$$P_{co} = e_0 \cdot f^3 + e_1 \cdot f^2 + e_2 \cdot f + e_3 \quad (10)$$

where P_{co} is the real-time power consumption of the cooling tower, f represents its operating frequency.

The model parameters for various components of the central cooling system were determined through experimental fitting and existing literature review, as listed in Table 4.

Table 4. Model parameters.

Model Parameters	Value
a_1	−0.41527
a_2	−0.49308
a_3	−0.00521
a_4	2.88287
a_5	13.45778
a_6	−0.01786
a_7	4.96740
a_8	8.52341
b_1	−0.02668
b_2	6.35890
b_3	−4.33009
b_4	−0.00268
b_5	1.03823
b_6	−0.20544
e_0	0.00000381
e_1	0.0001815
e_2	−0.0064332
e_3	0.091875

2.2.3. Battery

This paper utilizes the Deli NP100-12UPS model of storage battery, which is a 12 V, 100 Ah lead-acid battery. When there is renewable electricity, the excess energy is stored in the battery. When the renewable electricity is insufficient to meet the load demand, the stored energy in the battery is discharged.

The state of charge (SOC) is commonly used to represent the charging and discharging process of a battery.

Charging:

$$SOC(t) = SOC(t - \Delta t) + \frac{P_{bat}\eta_b\Delta t}{N_{bat}} \quad (11)$$

Discharging:

$$SOC(t) = SOC(t - \Delta t) + \frac{P_{bat}\Delta t}{N_{bat}\eta_b} \quad (12)$$

where Δt is the time duration for charge or discharge. P_{bat} is the charge and discharge power (positive value is charge, while negative value is discharge). η_b is the charge and discharge efficiency, which is 0.95 in this paper. N_{bat} is the battery capacity.

2.2.4. Ice Tank

As the cooling energy storage device in the integrated energy system, the ice storage tank enables peak shaving and valley filling. By leveraging time-of-use electricity pricing strategies, it stores cooling energy via ice formation during off-peak nighttime hours and releases stored energy during daytime peak periods. This operational strategy significantly reduces cooling costs during high-tariff intervals and alleviates grid load pressure [39].

Under ice storage mode, the ice storage rate can be considered constant [40]. The energy conversion efficiency from the chiller to the ice storage is influenced by losses in the distribution network and the operational characteristics of the ice storage equipment. The real-time ice storage capacity is expressed as:

$$Q_i = \eta \cdot \sum_{n=1}^N \sum_{t=t_0}^{t_k} PLR_n(t) \cdot Q_{n,cap}(t) \quad (13)$$

where η is the cooling capacity conversion efficiency, set as 0.96. N represents the number of ice-making units. t_0 and t_k are the start and end times of the ice-making cycle, respectively. $PLR_n(t)$ indicates the partial load ratio of the n -th ice-making unit at time t . $Q_{n,cap}$ is the rated cooling capacity of the n -th ice-making unit, kW.

The ice melting rate is time-varying. In ice storage systems, the ice gradually melts inward from the outer layer of the storage tank. The thermal resistance of the ice-water mixture increases with melting duration, leading to a decay in melting rate, as depicted in the Figure 5. Studies [41] have demonstrated that the maximum instantaneous melting capacity during this process is a function of the remaining ice volume in the storage device.




Figure 5. Ice melting curve.

At time t , the maximum releasable cooling capacity of the ice storage tank is constrained by the residual ice volume and the instantaneous melting rate. The melting rate is formulated in Equations (14) and (15). This nonlinear melting model has been experimentally validated in Ref. [41].

$$\varepsilon_\beta = 0.1463 \cdot (1.1992 - \beta)/1.3176 \quad (14)$$

$$\beta = 1.1992 - 1.3176 \cdot e^{-1.11106t} \quad (15)$$

where β is the percentage of melted ice relative to the total ice storage capacity.

The maximum ice melting capacity of the ice storage tank at time t is:

$$Q_m = \frac{Q_{it} \cdot \varepsilon_\beta}{H} \quad (16)$$

where Q_{it} is the total capacity of the ice tank. H is the ice melting time.

2.3. Optimization Problem

2.3.1. Objective Functions

In the design of IES, this study considers the daily operating cost ($Cost$), CO₂ emission reduction rate ($CDERR$), and renewable energy utilization rate (RU) as objectives for optimizing the system from the perspectives of economy, environment, and energy.

$$\begin{cases} \min(Cost) \\ \max(CDERR) \\ \max(RU) \end{cases} \quad (17)$$

The daily operating cost is expressed as:

$$Cost = \frac{LCC}{N * 365} \quad (18)$$

LCC is the life cycle cost [42]. N is the life span of the system, which is 20 years in this study. It should be noted that the current economic assessment assumes constant component efficiency over the system lifetime and fixed energy prices.

$$LCC = ICC - \sum_{n=1}^N \frac{d_n}{(1+i)^n} tr + \sum_{n=1}^N \frac{a_n}{(1+i)^n} (1 - tr) + \sum_{r=1}^R \frac{ICC_n}{(1+i)^{rl_c}} (1 - tr) - \frac{s}{(1+i)^N} \quad (19)$$

where ICC is the initial capital cost of the system (US\$). i represents the interest rate, set at 7% in this study. d_n is the annual depreciation (US\$). tr indicates the tax rate, defined as 5% in this study. a_n is the annual maintenance and operational costs. R refers to the number of equipment replacements over the system lifecycle. ICC_n signifies the replacement cost of the n -th component. l_c is the lifecycle of the n -th replaced component. s stands for the system salvage value.

$$ICC = N_{PV}C_{PV} + N_{WT}C_{WT} + N_B C_B + N_{ICE}C_{ICE} \quad (20)$$

where N_{PV} and N_{WT} are the number of installed PV panels and Wind turbines in the system, respectively. N_B and N_{ICE} represent the capacity of the battery storage and ice storage tank, respectively (kWh); C is the unit cost of the equipment, defined as the price per unit quantity or capacity.

$$CDERR = \frac{m_{CO_2,tra} - m_{CO_2,new}}{m_{CO_2,tra}} \quad (21)$$

where $m_{CO_2,tra}$ and $m_{CO_2,new}$ are the CO₂ emission in the tradition energy supply mode and the proposed method in this paper.

The traditional energy supply mode typically generates electricity through coal combustion. The production of 1 kWh of electricity requires the consumption of 360 g of standard coal.

$$m_{CO_2,tra} = 0.36u_{CO_2}sum(E_{load} + E_{AC}) \quad (22)$$

$$m_{CO_2,new} = 0.36u_{CO_2}sum(E_{grid,in}) \quad (23)$$

where u_{CO_2} is the CO₂ emission of standard coal. $sum(E_{load})$ and $sum(E_{AC})$ are the total electric load and the total power of the air conditioning system. $sum(E_{grid,in})$ is the electricity purchased from the grid.

$$RU = 1 - \frac{sum(E_{grid,out})}{sum(P_{RE})} \quad (24)$$

where $sum(E_{grid,out})$ is the electricity sold to the grid. $sum(P_{RE})$ is the total RE power.

2.3.2. Decision Variables

Based on the composition and operational strategies of the IES, this optimization problem requires the determination of four key variables: N_{PV} , N_{WT} , N_B , N_{ICE} . N_B and N_{ICE} represent the energy storage capacity of the system. It should be noted that this optimization focuses solely on the design capacities of the system components. The operational dispatch follows fixed rule-based strategies as described in Section 2.1 and Figures 2 and 3.

2.3.3. Constraints

The constraints of an IES can be divided into equality constraints and inequality constraints.

Equality Constraints

The equality constraints primarily refer to the operational requirements and energy balance constraints of the system. The following equation gives the energy balance constraint at each time:

Electricity balance:

$$E_{pv,i} + E_{wt,i} = E_{load,i} + E_{AC} + d(E_{bat})_i + E_{grid,out,i} \quad (25)$$

where $d(E_{bat})_i$ is the battery electricity change at time period i .

Cooling balance:

Ice storage period:

$$Q_{AC,i} = Q_{storage,i} + Q_{load,i} \quad (26)$$

Ice melting period:

$$Q_{load,i} = Q_{storage,i} + Q_{AC,i} \quad (27)$$

Inequality Constraints

The inequality constraints primarily include constraints on equipment capacity, constraints on equipment power, constraints on states of equipment such as SOC of battery.

$$N_{PV}^{min} \leq N_{PV} \leq N_{PV}^{max} \quad (28)$$

$$N_{WT}^{min} \leq N_{WT} \leq N_{WT}^{max} \quad (29)$$

$$N_B^{min} \leq N_B \leq N_B^{max} \quad (30)$$

$$N_{ICE}^{min} \leq N_{ICE} \leq N_{ICE}^{max} \quad (31)$$

$$0 \leq Q_{ICE,STO} \leq Q_{ICE,STO}^{max} \quad (32)$$

$$0 \leq SOC(t) \leq 1 \quad (33)$$

2.4. Optimization Solution

2.4.1. Overview of PPO

As a prominent reinforcement learning algorithm, PPO is designed to optimize policies by iteratively updating them within a trust region, ensuring stable and efficient training [43]. Unlike traditional policy gradient methods, PPO introduces a clipped surrogate objective function to limit policy updates, preventing drastic changes that could destabilize learning. This mechanism balances exploration and exploitation by constraining the policy's deviation from its previous version. The core innovation of PPO lies in its clipped surrogate objective:

$$L^{CLIP}(\theta) = \widehat{E}_t[\min(r_t(\theta)\widehat{A}_t, \text{clip}(r_t(\theta), 1 - \epsilon, 1 + \epsilon)\widehat{A}_t)] \quad (34)$$

$$r_t(\theta) = \frac{\pi_\theta(a_t | s_t)}{\pi_{\theta_{old}}(a_t | s_t)} \quad (35)$$

where $\widehat{A}_t$ is the estimated advantage function at timestep t . $r_t(\theta)$ is the probability ratio between the new and old policies. ϵ defines the clipping range to prevent excessively large policy updates.

The Critic network in PPO estimates the state-value function, which is trained to minimize the mean squared error (MSE) between predicted and target values:

$$L^{VALUE}(\phi) = \widehat{E}_t[(V_\phi(s_t) - \widehat{R}_t)^2] \quad (36)$$

where $\widehat{R}_t$ is the discounted cumulative reward calculated using Generalized Advantage Estimation (GAE). The advantage function $\widehat{A}_t$ is derived as:

$$\widehat{A}_t = \widehat{R}_t - V_\phi(s_t) \quad (37)$$

PPO employs an Actor-Critic architecture. The Actor updates the policy $\pi_\theta(a | s)$ using the clipped objective L^{CLIP} , and the Critic updates the value function $V_\phi(s)$ via L^{VALUE} , providing a baseline to reduce variance in policy gradients. This dual-network design enables efficient exploration-exploitation trade-offs while maintaining training stability.

PPO's simplicity and robustness enable it to be widely applied in single-objective optimization tasks, such as robotic control and game playing. However, its reliance on a single reward function limits its adaptability to complex scenarios requiring multi-objective trade-offs (e.g., balancing energy efficiency, cost, and environmental impact). To address this, this study extends PPO to a multi-objective framework, addressing challenges in reward shaping and optimization stability through adaptive mechanisms.

2.4.2. MOPPO

Traditional PPO employs a scalar reward function $r(s,a) \in \widehat{R}$ to direct the agent toward optimizing a single objective, where policy gradient updates are dominated by the value function of that singular goal. In contrast, complex scenarios such as IES necessitate the simultaneous optimization of multi-dimensional objectives (e.g., economic efficiency, environmental sustainability, and energy utilization), which inherently constitutes a multi-objective optimization problem. To address this, the proposed framework confronts two critical challenges:

1. **Reward Dimensionality Expansion:** Multi-Objective Reinforcement Learning (MORL) redefines rewards as a vector $r(s,a) = [r_1, r_2, r_3]^T \in \widehat{R}^d$ where each dimension corresponds to a distinct objective (e.g., cost minimization, CO₂ reduction, and photovoltaic utilization).
2. **Pareto Optimality:** Optimization must generate a Pareto front (PF), representing a set of non-dominated trade-off solutions in the objective space.

To address these challenges, this study proposes a MOPPO framework, as outlined in Algorithm 1. Key innovations include:

Vectorized Reward Processing: Extends the scalar reward function in traditional single-objective reinforcement learning to a multi-dimensional vector form, explicitly preserving trade-offs among objectives.

Algorithm 1 Multi-Objective Proximal Policy Optimization

```

1  Initialize: Policy network  $\pi_\theta$ , value network  $V\phi$ , Pareto frontier
    $PF \leftarrow \emptyset$ , state normalizer  $Ns$ , reward normalizer  $Nr$ 
2  for episode = 1 to  $N_{max}$  do
3      Collect trajectory  $D = \{(st, at, rt)\}$  via  $\pi_\theta$ 
4      Update  $Ns$  with states,  $Nr$  with rewards
5      for step  $t = 1$  to T in episode do
6          Extract multi-objective reward vector  $rt = [r_t^1, \dots, r_t^M]$ 
7          if  $rt$  non-dominated by  $PF$  then
8              Remove solutions in  $PF$  dominated by  $rt$ 
9               $PF \leftarrow PF \cup \{rt\}$ 
10         end if
11     end for
12     for objective  $m = 1$  to M do
13         Compute  $A^m \leftarrow \text{GAE}(\lambda)$  using  $V\phi$ 
14     end for
15     Randomly select  $k$  solutions  $\{\mathbf{R}_p\}$  from  $PF$ 
16     Compute advantage direction:  $\bar{A} \leftarrow 1/k \sum_{p=1}^k (R_p - V_\phi(s)) \cdot A$ 
17     Update policy using  $\bar{A}$  as advantage signal
18     for epoch = 1 to K do
19         Compute value target:  $V_{target} \leftarrow V_\phi(s) + \bar{A}$ 
20         Update value network:  $\min_\phi \|V_\phi(s) - V_{target}\|_2^2$ 
21         Compute ratio  $\rho(\theta) \leftarrow \pi_\theta(a|s) / \pi_{old}(a|s)$ 
22         Calculate loss  $L_{clip} \leftarrow E[\min(y, \text{clip}(\rho, 1 \pm \epsilon)\bar{A})]$ 
23         Compute entropy  $L_{ent} \leftarrow H(\pi_\theta)$ 
24         Update  $\theta \leftarrow \text{Adam}(\nabla_\theta(L_{clip} + 0.01L_{ent}))$ 
25     end for
26 end for

```

Pareto Policy Selection: At the end of each training episode, non-dominated sorting is applied to state-action trajectories within the trajectory buffer to dynamically generate the current Pareto front. The frontier solution set directly guides policy network updates, ensuring balanced convergence across competing objectives.

In the design of IES, this study redefines the core elements of the reinforcement learning framework to accommodate multi-objective optimization:

State Space: The state vector $s = [s_1, s_2, s_3, s_4]$, where:

s_1 : installed capacity of PV (m^2). s_2 : installed capacity of wind turbine (number of units). s_3 : battery storage capacity (kWh). s_4 : ice storage tank capacity (kWh). Each state variable is normalized to the range $[0, 1]$ based on its predefined upper and lower bounds (as given in Section 2.3.3, Constraints).

Action Space: The action vector shares the same dimensionality as the state vector. Each dimension a_i governs the directional adjustment and magnitude of the corresponding state parameter s_i , thereby transforming the continuous design optimization problem into a learnable policy search process.

Reward: The reward vector is defined as $r = [r_1, r_2, r_3]^T$, where:

r_1 : $-Cost$ (negative daily operating cost, to be minimized). r_2 : $CDERR$ (CO₂ emission reduction rate, to be maximized). r_3 : RU (renewable energy utilization rate, to be maximized).

According to Algorithm 1, the workflow of MOPPO can be divided into four stages:

- (1) Multi-objective Reward Processing and Pareto Front Maintenance (Lines 4–7): At every step of episode, the multi-dimensional reward vector $r_t = [r_1, r_2, r_3]$ is extracted. To avoid dominance by any single objective during optimization due to differences in units and scales, all reward components are normalized to a comparable numerical interval. Specifically, each reward component r_i (*i.e.*, Cost, CDERR, RU) is normalized linearly to the range $[0, 1]$ based on the minimum and maximum values observed in the current Pareto front. This ensures that no objective inherently dominates the policy update because of its absolute magnitude. The normalized reward vector is then used for non-dominated sorting and advantage computation. The PF is dynamically updated based on non-dominated criteria: if r_t is not dominated by any solution in PF, it is added to PF, while existing solutions dominated by r_t are removed, which ensures PF consistently represents the optimal trade-off solutions. Thus, at each episode step, the reward vector of the current state-action trajectory is compared against all stored solutions in the Pareto set. Dominance is determined using standard Pareto dominance rules (*i.e.*, solution A dominates solution B if A is no worse than B in all objectives and strictly better in at least one). This mechanism guarantees that only non-dominated solutions are retained, and the frontier evolves monotonically toward the true Pareto front.
- (2) Advantage Computation (Lines 8–10): Instead of a scalar advantage, we compute a global advantage direction. k reference solutions $\{R_p\}$ are selected from PF. The advantage is then calculated as $\bar{A} = \frac{1}{k} \sum (R_p - V_\phi(s)) \cdot A$, where $\bar{A}$ is the original advantage from the critic. This projects the multi-objective reward differences into a scalar advantage that reflects the overall improvement direction toward the Pareto front.
- (3) Policy Network Optimization (Lines 11–15): The clipped surrogate objective of PPO is adapted to use this $\bar{A}$

$$L^{CLIP}(\theta) = \hat{E}[\min(r_t(\theta)\bar{A}, \text{clip}(r_t(\theta), 1 - \epsilon, 1 + \epsilon)\bar{A})] \quad (38)$$

An entropy regularization term $L_{ent} = H(\pi_\theta)$ is introduced to enhance exploration.

- (4) Critic Network Training (Lines 16–19): For M optimization objectives, critic networks $\{V_{\phi_m}\}$ are trained by minimizing the mean squared error (MSE), which provides accurate state-value estimates for each objective, enabling the actor to learn a policy that balances all objectives simultaneously.

2.4.3. MOPPO Evaluation

DTLZ2 and DTLZ5 are classic multi-objective optimization benchmarks designed to evaluate algorithmic performance in high-dimensional objective spaces, focusing on convergence, distribution characteristics, and adaptability to complex geometric structures. Specifically:

DTLZ2: Its PF is a segment of a hypersphere, serving to assess global convergence in uniformly distributed objective spaces. The mathematical formulation of DTLZ2 is given by:

$$\text{Minimize} \left\{ \begin{array}{l} f_1(x) = (1 + g(x)) \cos\left(\frac{x_1\pi}{2}\right) \cos\left(\frac{x_2\pi}{2}\right) \dots \cos\left(\frac{x_{M-2}\pi}{2}\right) \cos\left(\frac{x_{M-1}\pi}{2}\right) \\ f_2(x) = (1 + g(x)) \cos\left(\frac{x_1\pi}{2}\right) \cos\left(\frac{x_2\pi}{2}\right) \dots \cos\left(\frac{x_{M-2}\pi}{2}\right) \sin\left(\frac{x_{M-1}\pi}{2}\right) \\ f_3(x) = (1 + g(x)) \cos\left(\frac{x_1\pi}{2}\right) \cos\left(\frac{x_2\pi}{2}\right) \dots \sin\left(\frac{x_{M-2}\pi}{2}\right) \\ \vdots \\ f_k(x) = (1 + g(x)) \cos\left(\frac{x_1\pi}{2}\right) \dots \sin\left(\frac{x_{M-k+1}\pi}{2}\right) \\ \vdots \\ f_M(x) = (1 + g(x)) \sin\left(\frac{x_1\pi}{2}\right) \end{array} \right. \quad (39)$$

$$\text{Subject to: } 0 < x_i < 1, \forall i = 1, 2, \dots, n \quad (40)$$

$$\text{where: } g(x) = \sum_{i=M}^n (x_i - 0.5)^2 \quad (41)$$

DTLZ5: By introducing nonlinear variable correlations, it constructs a non-uniform PF to test solution uniformity and local search capability in geometrically complex scenarios. The mathematical formulation of DTLZ5 is given by:

$$\text{Minimize} \left\{ \begin{array}{l} f_1(x) = (1 + g(x)) \cos\left(\frac{\theta_1\pi}{2}\right) \cos\left(\frac{\theta_2\pi}{2}\right) \dots \cos\left(\frac{\theta_{M-1}\pi}{2}\right) \\ f_2(x) = (1 + g(x)) \cos\left(\frac{\theta_1\pi}{2}\right) \cos\left(\frac{\theta_2\pi}{2}\right) \dots \sin\left(\frac{\theta_{M-1}\pi}{2}\right) \\ \vdots \\ f_k(x) = (1 + g(x)) \cos\left(\frac{\theta_1\pi}{2}\right) \dots \sin\left(\frac{\theta_{M-k+2}\pi}{2}\right) \\ \vdots \\ f_M(x) = (1 + g(x)) \sin\left(\frac{\theta_1\pi}{2}\right) \end{array} \right. \quad (42)$$

$$\text{Subject to: } 0 < x_i < 1, \forall i = 1, 2, \dots, n \quad (43)$$

$$\theta = \begin{cases} \frac{\pi}{4(1 + g(x))} (1 + 2g(x)x_i) & i = 1 \\ \frac{\pi}{4(1 + g(x))} (1 + 2g(x)x_i) & i = 2, 3, \dots, n \end{cases} \quad (44)$$

$$g(x) = \sum_{i=M}^n (x_i - 0.5)^2 \quad (45)$$

The Inverted Generational Distance (IGD) is a multi-objective optimization performance metric that evaluates the distribution and convergence of solution sets by calculating the average Euclidean distance between the algorithm-derived solutions and the true Pareto front. A smaller IGD value indicates closer proximity to the true front and better distribution uniformity. The key parameter configurations for MOPPO, MOPSO, and MOSFO are shown in Table 5.

Table 5. Algorithm parameters.

Algorithm	The Setting of the Relevant Parameters
MOPPO	Episode = 200, step = 10, boundary of action = [0, 1], gamma = 0.99
MOPSO	MaxIt = 200, Pop = 50, $\omega = 0.5$
MOSFO	MaxIt = 200, Pop = 50, pollination rate = 0.1, mortality rate = 0.1

2.4.4. Decision-Making Method

It is noteworthy that the Pareto front inherently characterizes a fundamental attribute of multi-objective optimization problems: trade-offs exist among competing objectives, making it impossible to achieve optimal results for all of them. Consequently, no single solution absolutely dominates all others. To resolve this decision-making challenge, this study employs the Technique for Order Preference by Similarity to Ideal Solution (TOPSIS) for further refinement and ranking of the Pareto solution set.

The core concept of TOPSIS lies in constructing positive and negative ideal solutions within the multi-objective space, then measuring the Euclidean distance between each candidate solution and these reference points. The relative closeness derived from these distances serves as the metric for solution ranking. To eliminate dimensional heterogeneity among objectives, all objective values undergo normalization via linear scaling to the $[0, 1]$ interval prior to distance computation. For the normalized value z_{ij} the j -th objective in the i -th solution, the following formulation applies:

$$Z = \begin{cases} \frac{x_{ij} - x_j^{\min}}{x_j^{\max} - x_j^{\min}} \\ \frac{x_j^{\max} - x_{ij}}{x_j^{\max} - x_j^{\min}} \end{cases} \quad (46)$$

The positive ideal solution Z^+ and negative ideal solution Z^- are defined as the sets of maximum and minimum values across all normalized objectives, respectively. Subsequently, the Euclidean distances between the i -th solution and these ideal references are computed as follows [44]:

$$D_i^+ = \sqrt{\sum_{j=1}^m (z_{ij} - z_j^+)^2} \quad (47)$$

$$D_i^- = \sqrt{\sum_{j=1}^m (z_{ij} - z_j^-)^2} \quad (48)$$

The relative closeness is expressed as follow:

$$C_i = \frac{D_i^-}{D_i^+ + D_i^-} \quad (49)$$

A C_i value closer to 1 indicates better solution performance.

3. Case Study

3.1. Meteorological and Load Analysis

The building electricity and cooling load data used in this study were obtained through an 8760-h annual dynamic simulation of an office building in Shanghai using EnergyPlus. The meteorological data, sourced from the Shanghai Typical Meteorological Year (TMY) file available at <https://energyplus.net/weather> (accessed on 8 October 2024), include hourly dry-bulb temperature, relative humidity, solar irradiance (direct and diffuse), and wind speed.

The annual solar radiation, temperature, as well as wind speed variation profiles are shown in Figure 6. It can be seen that the solar radiation is concentrated from late spring to summer, characterized by high intensity and long duration, while the temperature exhibits distinct seasonal fluctuations, with prolonged higher temperatures in summer and lower temperatures in winter. The annual wind speed variation indicates that the region possesses relatively abundant wind resources, demonstrating potential to develop and utilize wind energy for RE generation.




Figure 6. Meteorological data. (a) Irradiance; (b) Temperature; (c) Wind speed.

Figure 7 illustrates the hourly cooling and electricity load profiles across summer, transitional seasons, and winter. In summer, the cooling load peaks during daytime hours, particularly from noon to afternoon, driven by intensive cooling demand. Transitional seasons exhibit significantly lower cooling loads, with minor fluctuations concentrated around midday. In contrast, winter cooling demand is negligible, reflecting minimal refrigeration requirements. Meanwhile, the electricity load consistently demonstrates a dual-peak pattern (midday and evening) throughout all seasons. However, the magnitude and temporal characteristics of these peaks are strongly modulated by seasonal cooling load variations.




Figure 7. Typical-day load profiles of different seasons. (a) Summer; (b) Transitional seasons; (c) Winter.

3.2. Parameter Settings

The parameter configuration for this case study comprises equipment economic parameters, energy pricing parameters, and algorithmic parameters. The specifications for the first two are detailed in Tables 6 and 7 [45], while the algorithmic parameters are given in Table 8.

Table 6. Economic parameters of each device.

Device	Value
PV	1.05 \$/W
Wind turbine	1.45 \$/W
Ice tank	0.5 \$/W
Battery	0.5 \$/W

Table 7. Time-of-use (TOU) Electricity Pricing Structure.

Period Type	Time Range	Value (US\$)
Peak	8:00–23:00	0.086
Off Peak	0:00–7:00	0.043
feed in tariff	0:00–23:00	0.056

Table 8. MOPPO and LSTM parameters.

		Item	Value
MOPPO		Episode	1000
		Step of every episode	2
		Hidden Layer Dimension	128
		Actor Learning Rate	0.0003
		Critic Learning Rate	0.00003
		Discount Factor (γ)	0.99
		Clipping Epsilon (ϵ)	0.2
		GAE parameter (λ)	0.95
		Entropy coefficient	0.01
LSTM		Train	80%
		Test	20%
		Learning rate	0.001
		Batch size	32
		R^2 (PV)	0.89
		RMSE (PV)	6.83%
		R^2 (wind)	0.87
		RMSE (wind)	8.41%

3.3. Wind and Solar Power Prediction Model

In this study, LSTM-based prediction models were developed for PV and wind power generation forecasting. The specifications of the components are provided in Table 9. The PV power model was trained using meteorological data and PV output records from the Alice Springs Solar Centre in Australia [46], with each PV unit having a rated capacity of 5.4 kW as the basic prediction unit, and was applied to estimate PV power generation in Shanghai. The wind power model was trained on wind speed and direction data from a wind farm in China [47], and was transferred to estimate wind power generation in Shanghai. This is under the assumption of similar PV and wind turbine characteristics. According to prior research by the author team [48,49], such model transfer methods based on physical similarity have been validated to be effective in cross-regional applications. The annual distributions of PV and wind power generation are illustrated in Figure 8.

Table 9. Rated Technical Parameters of PV Panels and Wind Turbines.

Device Type	Parameter	Value	Unit
PV	Panel Type	BP 3165	/
	Panel Rateing	165	W

WT	Panel Area	1.26	m ²
	Turbine Type	XE72	
	Capacity	2000	kW
	Hub height	65.0	m
	Rotor diameter	70.7	m




Figure 8. Wind and solar power forecasting. (a) Wind power forecasting; (b) PV power forecasting.

4. Results and Discussion

4.1. Comparison of Different Optimization Algorithms

This section presents a comprehensive performance evaluation of the proposed MOPPO algorithm, comparing it against state-of-the-art multi-objective optimization methods: Multi-Objective Particle Swarm Optimization (MOPSO) and Multi-Objective Sunflower Optimization (MOSFO). Two widely recognized multi-objective test functions (DTLZ2 and DTLZ5), together with the IGD, are adopted as the performance metrics to evaluate both distribution and convergence of the solution sets.

4.1.1. PF Analysis of MOPPO on Benchmark Problems

Figure 9 illustrates the three-dimensional comparison between the Pareto optimal solutions (blue points) generated by the MOPPO and the true PF (green points) for DTLZ2. The results show that MOPPO's solution set closely aligns with the true PF surface and exhibits a uniform distribution along the objective axes (f_1 , f_2 , and f_3), demonstrating its superior convergence and diversity preservation in balancing multi-objective conflicts.

MOPPO's solution set of DTLZ5 achieves precise coverage of the PF, as shown in Figure 10. Although the nonlinear objective correlations in the DTLZ5 problem pose significant optimization challenges, resulting in a slightly sparse distribution of solutions in the high- f_1 and high- f_2 regions compared to the

true PF, MOPPO demonstrates remarkable adaptability to nonlinear objective interactions, maintaining strong alignment with the true PF.




Figure 9. Pareto front of MOPPO tested on DTLZ2. (a) Front view; (b) Side view.




Figure 10. Pareto front of MOPPO tested on DTLZ5. (a) Front view; (b) Side view.

4.1.2. Convergence Analysis of MOPPO on Benchmark Problems

Figures 11 and 12 present the IGD convergence curves of the three algorithms tested with DTLZ2 and DTLZ5, respectively. MOPPO demonstrates significant advantages in both functions. For test function DTLZ2, MOPPO's IGD value rapidly declines at early iterations (<50) and stabilizes after approximately 150 iterations. This fast convergence stems from its policy gradient mechanism, which accurately captures intricate objective interactions and effectively resolves high-dimensional trade-offs. In contrast, MOPSO exhibits minor oscillations after 100 iterations due to parameter sensitivity and ultimately converges to a higher IGD value than MOPPO, indicating suboptimal convergence accuracy of the solution set. While MOSFO stagnates at higher IGD values owing to premature convergence, reflecting deviation from the true PF and poor distribution characteristics.




Figure 11. IGD convergence of DTLZ2.




Figure 12. IGD convergence of DTLZ5.

For test function DTLZ5, MOPPO's IGD curve shows a sharp initial descent. Conversely, MOPSO stalls in later iterations (>150) due to limited local search capability, and MOSFO experiences IGD rebound caused by distribution entropy fluctuations.

The average IGD convergence values of the three algorithms are presented in Table 10. These values were obtained by averaging the final converged IGD results from 50 independent runs on the benchmark problems. Compared to MOPSO and MOSFO, MOPPO achieves 20.8% and 64.0% lower IGD values on DTLZ2, and 41.2% and 75.3% lower on DTLZ5, respectively. These substantial reductions signify that MOPPO's solution sets exhibit significantly enhanced convergence precision when approximating the true PF.

Table 10. Performance of Algorithms on DTLZ2 and DTLZ3.

Algorithm	IGD of DTLZ2	IGD of DTLZ5
MOPPO	0.0680	0.0147
MOPSO	0.0859	0.0596
MOSFO	0.1890	0.0250

In summary, MOPPO not only maintains a uniform distribution of solutions in the objective space but also rapidly converges to the true PF. This dual advantage makes it particularly suitable for addressing complex multi-objective optimization problems.

4.2. Optimization Results

4.2.1. PF Analysis of MOPPO on IES

To verify the effectiveness and superiority of the proposed MOPPO algorithm in solving the optimal design of the IES, the MOPSO was introduced as a benchmark for comparison. Figure 13 illustrates the Pareto optimal frontiers obtained by MOPPO and MOPSO, explicitly revealing the trade-offs among operational cost, CDERR, and RU. The training of MOPPO on the IES design problem converged after approximately 800 episodes, as evidenced by the stabilization of the average episode reward and the hypervolume of the Pareto front. The PF of MOPPO exhibits the following characteristics: The optimal solution set for daily cost spans from \$8730.86 to \$15,064.02. Regarding environmental performance, CDERR values cover 48–60%, while the RU range spans 76–97%, with peak values occurring in high-cost regions.




Figure 13. Pareto frontier of the optimization. (a) Pareto of MOPPO; (b) Pareto of MOPSO.

Observation of the Pareto fronts reveals that the solution sets generated by MOPPO and MOPSO exhibit similar distribution trends and coverage ranges in the objective space. This similarity verifies the convergence capability of the MOPPO algorithm, demonstrating that the DRL-based approach can effectively approximate the true Pareto front.

Further analysis of the Pareto front reveals intricate interactions among the three objectives. As RU approaches 1 (indicating near-full renewable utilization), the system requires a high penetration of renewable generation, leading to substantial initial investment costs and consequently an increase in total cost. Concurrently, the CDERR exhibits a slight decline. This inverse relationship originates from an inherent conflict between the optimization objectives: the definition of the RU (Equation (24)) rate inherently discourages electricity sales, while the definition of the CDERR (Equation (21)) necessitates maximizing the total generation from renewables. Consequently, the pursuit of a higher renewable energy utilization rate inhibits the deployment of large-scale renewable capacity to avoid power sales, thereby limiting the achievable carbon emission reduction rate.

The solution distribution shows dense clustering in economically favorable low-cost regions, offering decision-makers flexible options to balance environmental targets within budget constraints. For instance,

In scenarios with high carbon trading costs or stringent emission mandates, solutions prioritizing CDERR can be selected. Under energy cost pressures, solutions near the low-cost Pareto region are optimal.

4.2.2. Comprehensive Evaluation of Pareto-Optimal Solutions Using TOPSIS Method

Table 11 presents the comparison of the final optimal design solutions selected by TOPSIS for both algorithms. As indicated in Table 3, although both algorithms provide feasible design schemes, the optimal solution derived from MOPPO outperforms the MOPSO solution in terms of comprehensive performance. Specifically, the MOPPO solution achieves a lower Cost of \$16,834.87, representing a 6.52% reduction compared to the \$18,009.32 cost of MOPSO. Furthermore, MOPPO demonstrates superior environmental performance, with a CDERR of 59.49%, corresponding to a 9.54% improvement over MOPSO. This superiority can be attributed to the proximal policy optimization mechanism, which enables more stable updates and fine-grained search in the continuous action space of equipment capacity configuration. Consequently, the MOPPO-optimized configuration was selected as the final design scheme for further analysis in the subsequent sections.

Table 11. Optimal capacity configuration.

Algorithm	Cost	CDERR	RU	PV	WT	Battery	Ice Tank
MOPPO	16,834.87	59.49	87.02	824	4	9301	37,949
MOPSO	18,009.32	54.31	89.96	765	4	9283	39,727
Unit	USD	%	%	m ²	-	kWh	kWh

4.3. Analysis of Energy and Economy

In this section, the cooling and electricity balance analysis are presented to show the operational strategies of the IES.

4.3.1. Cooling and Electricity Balance

As illustrated in the typical daily electricity balance diagrams for summer, winter, and the transitional seasons in Figure 14, the system shows clear seasonal differences in demand profile, RE usage, and battery storage strategies. During the summer period, the electricity demand between 0:00–5:00 remains relatively higher compared to other seasons due to significantly increased cooling requirements. Wind power generation is insufficient during the 00:00–01:00 and 03:00–05:00 periods. To meet the load gap, the system satisfies the load demand through battery discharge and purchasing power from the grid. After 12:00, except for a local peak at 17:00, renewable energy generation is generally inadequate: photovoltaic power generation is constrained by installed capacity, and wind power output is intermittent, leading to occasional reliance on battery discharge.

In winter, electricity demand is relatively lower, and nighttime load decreases significantly. This is primarily because ice storage cooling mode is not activated in winter, and electricity is mainly used to meet basic cooling load. Although wind power generation is limited between 00:00 and 06:00, it still meets the baseline nighttime load demand, with surplus power used to charge the battery. Daytime wind power exhibits significant fluctuations: except for the peak in wind power generation between 09:00 and 11:00, renewable energy output is noticeably lower during other periods. The battery is depleted by 11:00 and remains at a 0% SOC thereafter. The system primarily relies on grid power to maintain stable operation. By midday, the battery is often fully discharged, and the system relies on grid electricity. Unlike summer, no ice storage is used, and the operational strategy focuses purely on electricity balance.

Transition seasons demonstrate significant advantages in wind power resources. Between 02:00–06:00 and 08:00–12:00, The system prioritizes storing excess electricity in the battery, and by 12:00, the battery's

SOC reaches the upper limit of its rated capacity. Thereafter, all excess wind power is directly transmitted to the grid between 12:00 and 18:00. Throughout this period, the battery remains fully charged at its maximum capacity. This operational mode not only facilitates the utilization of renewable energy but also significantly enhances the system's economic performance via revenue generated from electricity sales.




Figure 14. Electricity balance of the system. (a) Summer; (b) Winter; (c) Transition season.

The cooling balance across seasons is illustrated in Figure 15. Summer is characterized by high cooling demand and strong solar irradiance, but moderate wind speeds. Due to the temporal mismatch between solar generation and cooling demand, the system relies heavily on ice storage to shift cooling loads. By relying on overnight ice storage, the system meets part of the daytime cooling demand in summer. Specifically, during the nighttime period from 00:00 to 05:00, the system initiates ice-making mode to convert electrical energy into ice for cooling storage. This ice-storage strategy reduces peak power demand during daytime operation. The discharge process of the ice storage from 10:00 to 22:00 shows a gradual decrease in the cooling energy supplied by the ice tank, attributable to the declining melting rate as discussed in Section 2.2.4. It is noteworthy that no ice charging occurs at 17:00, as this period coincides with the peak wind power generation shown in Figure 14. The system prioritizes the use of green electricity to directly drive the chillers for cooling, thereby reducing ice consumption and enhancing the utilization of clean energy.

Because of the residual ice from the previous day, less ice is stored at night on the typical transitional season day than on a summer day. As shown in Figure 15, the duration of ice storage operation in these seasons is only 3 h, significantly shorter than the 6 h in summer. During the daytime (08:00–18:00) of that day, wind and photovoltaic power generation are relatively abundant, enabling renewable electricity to directly power the chillers and meet most of the cooling demand. As a result, the ice storage system remains in standby mode. Between 19:00 and 21:00, when renewable generation declines, the system activates the

ice storage to discharge cooling energy, supplementing the chiller output to ensure stable coverage of the cooling load.




Figure 15. Cooling balance. (a) Summer; (b) Transition season.

Throughout the summer, the ITES effectively shifts daytime peak electricity demand via coordinated charging and discharging strategies. By prioritizing direct use of surplus green electricity for cooling, the system not only guarantees cooling reliability but also improves economic and environmental performance. In transitional seasons, the operational strategy focuses on maximizing renewable energy consumption, with the ice storage system serving as a supplementary regulation measure. This further enhances the utilization of clean energy and increases the overall economic efficiency of the system.

4.3.2. Seasonal Power Generation Analysis

Figure 16 depicts the energy mix of the system. The results reveal the dominance of RE sources, which maintains a share between 76.7% and 86.8%. It should be noted that the term “Renewable” here refers to

direct generation from sources such as wind and PV, while the electricity labeled as “Battery” also originates entirely from renewable sources. Essentially, battery storage captures surplus renewable electricity and discharges it when needed, thereby enabling a temporal shift in the power supply. Renewable contribution reaches its lowest level, at 76.7%, during summer. This decline stems from seasonal attenuation in wind power output and high cooling loads, which elevate grid-supplied electricity to 20.8%. Winter shows negligible cooling demand, and the ice storage system is not activated. The electricity load is dominated by lighting and office equipment. Wind power is generally stronger in winter due to seasonal monsoon effects, contributing to a renewable share of 80.9%.




Figure 16. Seasonal energy mix composition.

Concurrently, battery output rises to 6.8%, indicating the effectiveness of storage system integration in managing renewable generation. Transition seasons demonstrate optimal performance where mild climates ensure stable wind output and photovoltaic generation, minimizing grid reliance to 7.7%.

Such power generation behavior confirms the climatic resilience of IES. During transition seasons, 92.3% of electricity comes from clean energy sources—renewables together with battery storage. In extreme seasons, grid support becomes essential to maintain power supply reliability. Future optimization can prioritize long-term storage to further reduce dependence on grid supply.

In summary, the seasonal analysis reveals that: (i) summer is the most challenging season due to high cooling demand and moderate wind resources, requiring ice storage and grid backup; (ii) winter relies on battery storage to manage wind variability, with no cooling demand; (iii) transition seasons achieve near-grid-independence through abundant wind resources and low cooling loads. These seasonal differences justify the need for a multi-objective optimization that accounts for year-round performance rather than a single representative day.

4.4. Sensitivity Analysis

4.4.1. Sensitivity Analysis of Design Parameters

In order to further investigate the relationships between the design variables and the objectives, a sensitivity analysis was conducted. The results are shown in Figure 17. The analysis indicates a significant strong correlation between the number of wind turbines and the objective functions. The number of wind turbines is negatively correlated with LCC, demonstrating that increasing the number of turbines significantly reduces system costs. Concurrently, a strong negative correlation exists between the number of wind turbines and the RU. This is primarily attributed to the fact that an increased number of turbines leads to a higher proportion of excess electricity being sold back to the grid, which consequently reduces the system's renewable energy self-sufficiency. This demonstrates the multifaceted effects of turbine quantity on system performance, necessitating comprehensive trade-offs between cost-effectiveness and dependence on the grid.




Figure 17. Sensitivity analysis heatmap.

Although PV area exhibits a relatively smaller impact on the objective function, it contributes positively to improving energy efficiency, particularly in enhancing the system's green benefits. However, the installation of the PV panels is limited by the roof areas. Ice storage capacity shows a positive correlation with LCC, indicating a marginal increase in system lifecycle cost. Nevertheless, it plays an important role in boosting energy utilization efficiency by shifting system load.

Overall, the number of wind turbines exerts the most significant influence during optimization, significantly reducing the LCC of the system while enhancing energy utilization efficiency through improved RE accommodation, and elevating environmental quality via clean energy substitution. Other design variables—PV area, battery capacity, and ice storage capacity—demonstrate varying degrees of impact but remain essential contributors to the optimization process.

Regarding inter-variable relationships, a weak positive correlation exists between the number of wind turbines and battery capacity. This means a potential complementary coordination may emerge during system scaling. For example, batteries could store extra wind power when it's windy and supply power when the wind slows down. Conversely, a negative correlation between the number of wind turbines and ice storage capacity implies a possible competitive relationship in system design. For instance, with an increase in wind turbines, more renewable energy can be used to power the chillers. The requirement of ice storage is reduced. Furthermore, the positive correlation between ice storage capacity and LCC underscores its substantial contribution to economic burden. In contrast, battery capacity has a weaker impact on cost, indicating that battery energy storage has a comparative advantage over ice storage in terms of economic viability.

4.4.2. Analysis of System Optimization Triggered by Ice Storage Cost

With the continuous technology advancement and large-scale application of ice storage, the unit investment cost is expected to decline steadily. To prospectively evaluate the positive influence of this trend on future integrated energy systems, Figure 18 analyzes the critical role of ice storage unit cost in the optimal configuration of the system.




Figure 18. Ice storage cost impact on system optimization.

The results indicate that the decrease in the unit cost of the ice storage system not only significantly increases the installed capacity of the ice storage but also triggers an optimization effect on other components of the system. The battery capacity decreases from 9301 kWh to 8765 kWh, which is primarily

attributed to the fact that the ice storage system partially substitutes the “peak shaving” function of the battery by shifting cooling loads and reducing daytime electricity peaks, thereby economically reducing the demand for battery capacity. Furthermore, the capacity of renewable energy generation also increases accordingly. This is due to growing electricity demand for ice-making driven by expanded ice storage capacity, as well as the need to generate more power in real time to match daytime loads to compensate for the reduction in battery storage capacity.

In terms of energy, the proportion of grid power supply significantly decreases from 28.9% to 15.3%. This reduction stems from the excellent peak shaving and valley filling capabilities of the ice storage system, synergizing with the increased RE capacity. This combination markedly reduces reliance on the grid during peak periods while promoting the integration of renewable energy.

5. Conclusions

This study proposes an IES incorporating PV, wind turbine, battery storage, ice storage, chillers, and the power grid. An improved MOPPO reinforcement learning algorithm is introduced to address the multi-objective optimization design problem for this system. The algorithm demonstrates suitability for multi-objective reinforcement learning problems. Its effectiveness is validated using standard test functions, and a comprehensive analysis of the system’s energy economics is conducted. Key findings are summarized as follows:

- (1) The superior performance of the improved MOPPO algorithm is validated on standard multi-objective test functions DTLZ2 and DTLZ5. The obtained Pareto fronts closely approximate the true Pareto fronts. When compared with multi-objective metaheuristic algorithms (MOPSO and MOSFO), MOPPO achieves significant reductions in IGD values of 20.8–64.0% on DTLZ2 and 41.2–75.3% on DTLZ5, indicating markedly improved solution accuracy and convergence.
- (2) The improved MOPPO is successfully applied to the optimal design of the IES. The TOPSIS method is used for decision-making, demonstrating that the optimal solution derived from MOPPO outperforms the MOPSO benchmark, achieving a 6.52% reduction in daily operating costs and a 9.54% improvement in the carbon dioxide emission reduction rate.
- (3) Analysis of daily operation across seasons indicates that the designed IES effectively balances the supply and demand. This is achieved through the synergistic operation of electrical and ice storage to enhance system flexibility and efficiency. Battery storage plays a crucial role in storing surplus renewable generation during peak production periods and discharging it to cover supply shortfalls. Simultaneously, the ice storage system significantly contributes to load management by shifting cooling demand from peak to off-peak hours, which effectively reduces daytime electrical loads and enhances the utilization of overnight excess renewable energy. This strategy not only flattens the daily load profile but also significantly increases the self-consumption of renewable energy.
- (4) This study further reveals that a 40% reduction in ice storage unit cost leads to a 6.3% increase in its stalled capacity and a corresponding 5.7% decrease in battery capacity, demonstrating a clear technological substitution effect. Meanwhile, grid dependence decreased significantly from 28.9% to 15.3%, highlighting the system’s improved economic efficiency and renewable self-consumption capability. These findings underscore the importance of cost-effective ice storage in developing future low carbon buildings.

It should be noted that while this study has taken into account factors such as equipment aging and operational maintenance costs, the modeling approach remains relatively simplified. In practical engineering applications, more refined and dynamic modeling analysis tailored to specific scenarios is required. Future work will focus on developing highly detailed models considering equipment performance degradation and energy price uncertainty.

Statement of the Use of Generative AI and AI-Assisted Technologies in the Writing Process

During the preparation of this manuscript, the authors used Generative AI for language polishing and grammar checking. After using this tool, the authors reviewed and edited the content as needed and take full responsibility for the content of the published article.”

Author Contributions

Conceptualization, X.Y. Yang and Y. Li; Methodology, X.Y. Yang; Software, X.Y. Yang; Validation, X.Y. Yang and Y. Li; Formal Analysis, X.Y. Yang; Investigation, X.Y. Yang; Resources, Y. Li; Data Curation, X.Y. Yang; Writing—Original Draft Preparation, X.Y. Yang; Writing—Review & Editing, X.Y. Yang and Y. Li; Visualization, X.Y. Yang; Supervision, Y. Li; Project Administration, Y. Li. All authors have read and agreed to the published version of the manuscript.

Ethics Statement

Not applicable.

Informed Consent Statement

Not applicable.

Data Availability Statement

The data presented in this study are available from the corresponding author upon reasonable request.

Funding

This research received no external funding.

Declaration of Competing Interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Abbreviations

Abbreviations

IES	Integrated energy system
DESSs	Distributed energy systems
ACO	Ant Colony Optimization
PV	Photovoltaic
SOC	State of charge
ESSs	Energy storage systems
PSO	Particle Swarm Optimization
RE	Renewable energy
ITES	Ice thermal energy storage
NSGA	Non-dominated Sorting Genetic Algorithm
LCC	Lifecycle cost
ICC	Initial capital cost
CDERR	CO ₂ emission reduction rate
RU	Renewable energy utilization rate
EMA	Evolutionary Mating Algorithm
DRL	Deep Reinforcement Learning
PPO	Proximal Policy Optimization
NPV	Net present value

PF	Pareto front
LSTM	Long Short-Term Memory
Symbols	
Q_c	real-time cooling capacity
Q_e	real-time condensing heat output
$G_{w,c}$	cooling water mass flow rate
$G_{w,e}$	chilled water mass flow rate
P_c, P_e	power consumption of the cooling water pump and the chilled water pump
P_{co}	real-time power consumption of the cooling tower
Δt	time duration for charge or discharge
P_{bat}	charge and discharge power
C_{bat}	battery capacity
$PLR_n(t)$	partial load ratio of the n -th ice-making unit at time t
$Q_{n,cap}$	rated cooling capacity of the n -th ice-making
Q_{it}	total capacity of the ice tank
H	ice melting time
Q_m	maximum ice melting capacity
N	life span of the system
t_r	tax rate
a_n	annual maintenance and operational costs
R	number of equipment replacements over the system lifecycle
N_{PV}, N_{WT}	area of installed PV panels and number of wind turbines in the system
N_B/N_{ICE}	capacity of the battery storage/ice storage tank
$\widehat{A}_t$	estimated advantage function at timestep t
$r_t(\theta)$	probability ratio between the new and old policies
Greeks	
η	The cooling capacity conversion efficiency
β	The percentage of melted ice relative to the total ice storage capacity.
ϵ	clipping range to prevent excessively large policy updates.

References

1. IEA. Buildings—Energy System. Available online: <https://www.iea.org/energy-system/buildings> (accessed on 1 April 2025).
2. Xiong J, Ye Y, Wang Q, Dong X, Lu T, Ma D. A comprehensive review on distributed energy cooperative control and optimization method for energy interconnection system. *Electr. Power Syst. Res.* **2024**, *237*, 111007. DOI:10.1016/j.epsr.2024.111007
3. Wang M, Yu H, Yang Y, Lin X, Guo H, Li C, et al. Unlocking emerging impacts of carbon tax on integrated energy systems through supply and demand co-optimization. *Appl. Energy* **2021**, *302*, 117579. DOI:10.1016/j.apenergy.2021.117579
4. Sehar F, Pipattanasomporn M, Rahman S. An energy management model to study energy and peak power savings from PV and storage in demand responsive buildings. *Appl. Energy* **2016**, *173*, 406–417. DOI:10.1016/j.apenergy.2016.04.039
5. Ullah K, Ali S, Khan TA, Khan I, Jan S, Shah IA, et al. An Optimal Energy Optimization Strategy for Smart Grid Integrated with Renewable Energy Sources and Demand Response Programs. *Energies* **2020**, *13*, 5718. DOI:10.3390/en13215718
6. Karimi H. A tri-objectives scheduling model for renewable-hydrogen-based microgrid system considering hydrogen storage system and demand-side management. *Int. J. Hydrogen Energy* **2024**, *68*, 1412–1422. DOI:10.1016/j.ijhydene.2024.04.330
7. Zhu X, Gui P, Zhang X, Han Z, Li Y. Multi-objective optimization of a hybrid energy system integrated with solar-wind-PEMFC and energy storage. *J. Energy Storage* **2023**, *72*, 108562. DOI:10.1016/j.est.2023.108562
8. Hua LG, Bilal M, Hafeez G, Ali S, Alghamdi B, Alsafran AS, et al. An energy-efficient system with demand response, distributed generation, and storage batteries for energy optimization in smart grids. *J. Energy Storage* **2025**, *117*, 115491. DOI:10.1016/j.est.2025.115491
9. Sabareesh SU, Aravind KSN, Chowdary KB, Syama S, Devi VSK. LSTM Based 24 hours Ahead Forecasting of Solar PV System for Standalone Household System. *Procedia Comput. Sci.* **2023**, *218*, 1304–1313. DOI:10.1016/j.procs.2023.01.109

10. Cui X, Zhu J, Jia L, Wang J, Wu Y. A novel heat load prediction model of district heating system based on hybrid whale optimization algorithm (WOA) and CNN-LSTM with attention mechanism. *Energy* **2024**, *312*, 133536. DOI:10.1016/j.energy.2024.133536
11. Liu B, Xie Y, Wang K, Yu L, Zhou Y, Lv X. Short-Term Multi-Step Wind Direction Prediction Based on OVMD Quadratic Decomposition and LSTM. *Sustainability* **2023**, *15*, 11746. DOI:10.3390/su15111746
12. Wang L, Mao M, Xie J, Liao Z, Zhang H, Li H. Accurate solar PV power prediction interval method based on frequency-domain decomposition and LSTM model. *Energy* **2023**, *262*, 125592. DOI:10.1016/j.energy.2022.125592
13. Chen B, Li Z, Li S, Zhao Q, Liu X. A Wind Power Prediction Framework for Distributed Power Grids. *Energy* **2024**, *121*, 1291–1307. DOI:10.32604/ee.2024.046374
14. Ma Y. Multi-objective optimization model and algorithm implementation of the distributed power generation system for renewable energy in China and Russia. *Unconv. Resour.* **2025**, *7*, 100201. DOI:10.1016/j.uncres.2025.100201
15. Wang C, Jiao S, Zhang Y, Li Y, Li Y, Zhang Q. A new transfer evolutionary multi-task optimization algorithm for bi-level optimal configuration of distributed generations and energy storage systems considering uncertainties. *J. Energy Storage* **2025**, *113*, 115556. DOI:10.1016/j.est.2025.115556
16. Yau YH, Rismanchi B. A review on cool thermal storage technologies and operating strategies. *Renew. Sustain. Energy Rev.* **2012**, *16*, 787–797. DOI:10.1016/j.rser.2011.09.004
17. Curto D, Favuzza S, Franzitta V, Guercio A, Amparo Navarro Navia M, Telaretti E, et al. Grid Stability Improvement Using Synthetic Inertia by Battery Energy Storage Systems in Small Islands. *Energy* **2022**, *254*, 124456. DOI:10.1016/j.energy.2022.124456
18. Saffari M, de Gracia A, Fernández C, Belusko M, Boer D, Cabeza LF. Optimized demand side management (DSM) of peak electricity demand by coupling low temperature thermal energy storage (TES) and solar PV. *Appl. Energy* **2018**, *211*, 604–616. DOI:10.1016/j.apenergy.2017.11.063
19. Al-Aali I, Narayanaswamy A, Modi V. Design of chiller system with thermal and battery storage for enhanced integration with on-site PV. *J. Build. Eng.* **2024**, *87*, 109072. DOI:10.1016/j.jobee.2024.109072
20. Al-Aali I, Modi V. Decarbonizing the electricity sector in Qatar using PV combined with ice thermal and battery storage. *Energy Strategy Rev.* **2022**, *44*, 101014. DOI:10.1016/j.esr.2022.101014
21. Odufuwa OY, Kusakana K, Numbi BP, Tartibu LK. Optimal energy management of grid-connected PV for HVAC cooling with ice thermal storage system. *J. Energy Storage* **2024**, *77*, 109844. DOI:10.1016/j.est.2023.109844
22. Luerssen C, Gandhi O, Reindl T, Sekhar C, Cheong D. Life cycle cost analysis (LCCA) of PV-powered cooling systems with thermal energy and battery storage for off-grid applications. *Appl. Energy* **2020**, *273*, 115145. DOI:10.1016/j.apenergy.2020.115145
23. Arévalo P, Benavides D, Lata-García J, Jurado F. Techno-economic evaluation of renewable energy systems combining PV-WT-HKT sources: Effects of energy management under Ecuadorian conditions. *Int. Trans. Electr. Energy Syst.* **2020**, *30*, e12567. DOI:10.1002/2050-7038.12567
24. Qiao Q, Yunusa-Kaltungo A, Edwards RE. Feature selection strategy for machine learning methods in building energy consumption prediction. *Energy Rep.* **2022**, *8*, 13621–13654. DOI:10.1016/j.egyr.2022.10.125
25. Cha JH, Park J, Yeon SH, Yoon Y, Lee KH. Particle Swarm Optimization for multi-chiller system: Capacity configuration and load distribution. *J. Build. Eng.* **2024**, *98*, 110953. DOI:10.1016/j.jobee.2024.110953
26. Chen C, Duan S, Cai T, Liu B, Hu G. Optimal Allocation and Economic Analysis of Energy Storage System in Microgrids. *IEEE Trans. Power Electron.* **2011**, *26*, 2762–2773. DOI:10.1109/TPEL.2011.2116808
27. Benfatma H, Khoudimi H, Bessedik B. Neural network and ACO algorithm-tuned PI controller for MPPT in a hybrid battery-supercapacitor energy storage system within DC micro-grid photovoltaic installations. *J. Energy Storage* **2025**, *120*, 116499. DOI:10.1016/j.est.2025.116499
28. Zakaria NF, Sulaiman MH, Mustaffa Z. Feature optimization with metaheuristics for Artificial Neural Network-based chiller power prediction. *J. Build. Eng.* **2025**, *105*, 112561. DOI:10.1016/j.jobee.2025.112561
29. Chen B, Zeng W, Nie H, Deng Z, Yang W, Yan B. Optimal load distribution control for airport terminal chiller units based on deep reinforcement learning. *J. Build. Eng.* **2024**, *97*, 110787. DOI:10.1016/j.jobee.2024.110787
30. Biemann M, Scheller F, Liu X, Huang L. Experimental evaluation of model-free reinforcement learning algorithms for continuous HVAC control. *Appl. Energy* **2021**, *298*, 117164. DOI:10.1016/j.apenergy.2021.117164
31. Mnih V, Kavukcuoglu K, Silver D, Rusu AA, Veness J, Bellemare MG, et al. Human-level control through deep reinforcement learning. *Nature* **2015**, *518*, 529–533. DOI:10.1038/nature14236
32. Peng H, Yuan D, Jiang K, Xu W. PPO-based fluctuation-consumption co-optimized energy management for wind-disturbed fuel cell hybrid electric flying car. *J. Power Sources* **2025**, *647*, 237349. DOI:10.1016/j.jpowsour.2025.237349

33. Ning D, Chen X, Chen J, Meng T, Xu B, Zhang H. PPO-MixClip: An energy scheduling algorithm for low-carbon parks. *Energy Rep.* **2024**, *12*, 4195–4207. DOI:10.1016/j.egyr.2024.09.042
34. Singh A, Panigrahi BK. A HEN-PPO strategy for home energy management system with reduce EV anxieties. *e-Prime Adv. Electr. Eng. Electron. Energy* **2024**, *10*, 100871. DOI:10.1016/j.prime.2024.100871
35. Bai L, Tan Z. Optimizing energy efficiency, thermal comfort, and indoor air quality in HVAC systems using a robust DRL algorithm. *J. Build. Eng.* **2024**, *98*, 111493. DOI:10.1016/j.job.2024.111493
36. Ge Y, Xie J, Chang J, Feng S. A multi-objective deep reinforcement learning method for intelligent scheduling of wind-solar-hydro-battery complementary generation systems. *Int. J. Electr. Power Energy Syst.* **2025**, *167*, 110635. DOI:10.1016/j.ijepes.2025.110635
37. Long Short-Term Memory—An Overview|ScienceDirect Topics. Available online: <https://www.sciencedirect.com/topics/engineering/long-short-term-memory> (accessed on 17 May 2025).
38. Diniz APM, Ciarelli PM, Salles EOT, Coco KF. Use of deep neural networks for clogging detection in the Submerged Entry Nozzle of the continuous casting. *Expert Syst. Appl.* **2024**, *238*, 121963. DOI:10.1016/j.eswa.2023.121963
39. Tang C, Li N, Bao L. Predictive Control Modeling of Regional Cooling Systems Incorporating Ice Storage Technology. *Buildings* **2024**, *14*, 2488. DOI:10.3390/buildings14082488
40. Kang J, Wang J, Liu C, Ye S, Yang M. Coordinated optimization of configuration and operation of a photovoltaic integrated building cooling system with electricity and ice storages under source-load uncertainties. *Energy Build.* **2024**, *320*, 114600. DOI:10.1016/j.enbuild.2024.114600
41. Chen Q, Wei W, Li N. Techno-economic control strategy optimization for water-source heat pump coupled with ice storage district cooling system. *Int. J. Refrig.* **2022**, *138*, 148–158. DOI:10.1016/j.ijrefrig.2022.03.010
42. Ren X, Han Z, Ma J, Xue K, Chong D, Wang J, et al. Life-cycle-based multi-objective optimal design and analysis of distributed multi-energy systems for data centers. *Energy* **2024**, *288*, 129679. DOI:10.1016/j.energy.2023.129679
43. Schulman J, Wolski F, Dhariwal P, Radford A, Klimov O. Proximal Policy Optimization Algorithms. *arXiv* **2017**, arXiv:1707.06347. DOI:10.48550/arXiv.1707.06347
44. Dingcheng H, Metwally ASM, Ali S, Sillanpaa M, Yassen W, Sobhani B. Sustainable and environmentally-friendly multi-generation system of power, cooling, and hydrogen; Multi-objective optimization using particle swarm algorithm. *Appl. Therm. Eng.* **2023**, *225*, 120093. DOI:10.1016/j.applthermaleng.2023.120093
45. He W, Xu Q, Guo R, Liu S, Wang Y, Guo H, et al. Optimization analysis of different distributed energy configurations for data centers. *Sustain. Mater. Technol.* **2024**, *41*, e01005. DOI:10.1016/j.susmat.2024.e01005
46. DKA Solar Centre. Available online: <https://dkasolarcentre.com.au/> (accessed on 3 June 2025).
47. Chen Y, Xu J. Solar and wind power data from the Chinese State Grid Renewable Energy Generation Forecasting Competition. *Sci. Data* **2022**, *9*, 577. Available online: <https://www.nature.com/articles/s41597-022-01696-6> (accessed on 3 June 2025).
48. Yan R, Zhao T, Rezgui Y, Kubicki S, Li Y. Transferability and robustness of a data-driven model built on a large number of buildings. *J. Build. Eng.* **2023**, *80*, 108127. DOI:10.1016/j.job.2023.108127
49. Yan R, Chen Z, Zhang X, Zhao T, Rezgui Y, Li Y. A novel model ensemble method based on self-adaptive weight for building energy transfer learning. *J. Build. Eng.* **2025**, *109*, 113024. DOI:10.1016/j.job.2025.113024